



REQUIREMENTS:

Design and configuration: See figure 1.

Armored construction: Not acceptable.

Ratings:

Voltage: 120/208 volts, 3 phase Y.

Current: 30 amperes.

Frequency: 400 hertz.

Ⓐ Vibration: Method 204 of MIL-STD-202, test condition B (WC596/159-2 only).

Ⓐ Shock: Method 213 of MIL-STD-202, test condition I (WC596/159-2 only).

Mating connector: W-C-596/158.

Strain relief: Accommodate cable diameter .296-.625 inch (7.52-15.88 mm).

Part number: WC596/159-1, WC596/159-2 (ruggedized).

CONCLUDING MATERIAL

Custodians:

Army - CR

Navy - YD

Air Force - 85

Review activities:

Army - MI

Navy - EC, AS

Air Force - 11, 99

User activities:

Army - ME, AV

Navy - MC, SH

Preparing activity:

DLA - ES

Civil agency coordinating activities:

DCGOVT - DCG

DOT - ACO

GSA - FSS, PCD

HEW - FEC

Interior - BPA

USDA - BPA

(Project 5935-3660-12)

U.S. GOVERNMENT PRINTING OFFICE : 1988 - 201-766/81226

Orders for this publication are to be placed with General Services Administration, acting as an agent for the Superintendent of Documents. See section 2 of the general specification to obtain extra copies and other documents referenced herein.